



MPM416W/WK/WRK Submersible Level Transmitter

Features

- ·Separate construction; full sealed stainless steel construction for submersible/inserted sensor; aluminum-alloy electric connection box; easy for installation, wiring and calibration;
 - ·MPM416WK has stainless steel tube protection, flange installation, local display and calibration;
 - ·MPM416WRK is full welded, stainless steel flexible tube armoured;
- ·Explosion-proof version product conforms to Exia II CT6 of Standard GB3836.4; Explosion-proof Certificate is issued
- ·Ship-use product conforms to CCS Rules of Classification of Sea-going Steel Ships (2006); Ship-use Product Certificate is issued;
 - ·CE Certificate





MPM416W Submersible Level Transmitter

Level Hansmille

Introduction

MPM416W/MPM416WK/MPM416WRK Submersible Level Transmitters use high performance piezoresistive pressure sensor as sensing elements. It measures liquid static pressure accurately which is positive proportional to liquid depth, transmitting pressure signal into standard current/voltage output signal by amplifier circuit board. The product has high accuracy, compact size and easy operation characteristics, for it can be submersible into the liquid to measure level from transmitter bottom to liquid surface. For the liquid measure and control of both petroleum, chemi-industry, power station, city water supply and drainage and hydrology, it is widely used.

MPM416WK Submersible Level Transmitter




MPM416WRK Flexible Armoured Level Transmitter



Specifications

	MPM416W	1	2	5	10	20	50	100	200m	 nH₂∩	
Pressure range	MPM416WK	1		3	4ml			100	20011		
1 rocours range	MPM416WRK	1	2	5	10		ıH ₂ O				
Overpressure	1.5times FS	'				2011	11 120				
Accuracy	±0.25%FS (typ.)	+0	.5%F	-S (n	nax.)					
	$\pm 0.1\%$ FS (typ.) $\pm 0.2\%$ FS (max.) pressure range>20mH ₂ O								e>20mH ₂ O		
Stability error	±10mmH ₂ O (typ.) +20mmH ₂ O										
,	+20mmH ₂ O (typ.) +30mmH ₂ O										
							t,_+ %FS/℃			Sensitivitydrift, <u>+</u> %FS/℃	
	Rang>10mH ₂ O					0.01 (max.)			0.02 (max.)		
Temp. drift	Range ≤10mH ₂ C	O 0.01 (typ.)				0.02 (max.)			0.02 (max.)		
	Range ≤5mH ₂ O	0.015 (typ.)				0.03 (max.)			0.02 (max.)		
	Range ≤2mH ₂ O	0.025 (typ.)				0.05 (max.)			0.02 (max.)		
Transmitting	2-wire						3-wire			3-wire	
Dawarawali	15~30VDC (Intrinsic safe version is					3	15∼28VDC		`	15∼28VDC	
Power supply	supplied through safe barrier)						15/~26VDC			15~20100	
Output signal	4∼20mADC						0~10/20mADC		OC .	0/1∼5/10VDC	
Load (Ω)	< (U-15) /0.02A					<	< (U-15) /0.02A		02A	>5k	
	Housing: stainless ste MPM416W Diaphragm: stainless			steel 1	el 1Cr18Ni9Ti O-rin		O-rin	g: Viton			
Material				tainles	s stee	steel 316L Rubb			er casing: NBR		
contacting with		Cable: Ф7.2mm PVC/Polyurethane cable with vented							vented tube		
media	MPM416WK	Stainless steel 1Cr18Ni9Ti, red copper, Viton O-ring						O-ring			
	MPM416WRK	Stainless steel 1Cr18Ni9Ti									
Operation temp.	-10 °C ~80 °C; Intrinsic safe version: -10 °C ~60 °C										
Storage temp.	-40℃~100℃										
Protection	IP68 (sensor part) , IP65 (connection box)										
Ex-proof class	Exia II CT6										

Load Characteristic




2-wire 4∼20mADC output

15~30VDC power supply


$$R_{L} \leq \frac{U_{n} - 15V}{20mA} \times 10^{3} (\Omega)$$




Outline Construction and Electric Connection



Application Example






- 3 -




Connecting level transmitter with measure system.




Connecting Ex-proof version transmitter with safe barrier and measure displayer to build up measure and control system;


Connecting with MSB9418 measure displayer to displayer to build up one measure and control build up one liquid measure and control system with upper and lower limits alarming. Meanwhile, the displayer could output RS232 or analog signal 1~5VDC, 0~5VDC, 4~20mADC.



Connecting the most two level transmitter with MSB9438 measure displayer to build up one level difference system with multi-channel display. It can also output 4~20mADC analog output and provide upper



When measure static level in open tank, put level transmitter into tank bottom, and fix transmitter cable and connection box at the open tank entrance.





When measuring flow water, insert one steel tube Φ45 which has little holes Φ5 at different heights. Make holes opposite to water flowing direction, and let water go into the tube and fix cable

MPM416WK

-4-







Install in the flowing water

Install in static water


Thread Install in open oil tank

Flange install in open oil tank

Installation at Local Place

(Unit: mm)


MPM416W/WRK:



- 5 -



MPM416WK (The user needs to prepare flange and thread at local installation place)



Order Guide

MPM416W	Submersible										
MPM416WK	Armoured Level Transmitter										
MPM416WRK	Flexible Arn	Flexible Armoured Level Transmitter									
	range	[0∼X	L: cable	e length,	MPM416W						
	(mH ₂ O)	mH ₂ O]L	L: armo	oured tub	MPM416WK						
		IIII 2OJL	L: flexit	ole armou	MPM416WRK						
		Code	Output signal								
		E	4~20n	nADC							
		F	1~5VE	С							
			0~5VE	С							
		Q	0~10n								
		U	0~20n								
		V	0~10V	/DC							
			0 1	Construction material							
			Code	diaphragm		Pressure port	Housing				
			22	SS 3	16L	SS	SS				
			24	SS 3	16L	SS 316L	SS 316L				
			25	25 Tanta		SS	SS				
				Code		Others					
					0~10	00% hand pointer indicator (M	IPM416WRK has				
				M ₁	no thi	s option)					
				i	Intrinsic safe version Exia II CT6						
				C ₁	M20×1.5 male, face type seal G1/2 male		MPM416W				
				C ₃							
				C ₅	M20×	1.5 male, waterline seal					
				Т	Ship-ı	use					
				F ₁	Fixed	flange (MPM416WK has no f	this option)				



		2F2 2M2	DN10 Carbon steel plating zinc male	
		2F2	M42×1.5 Carbon steel plating zinc flange 2	
		2M1	Carbon steel plating zinc male	MPM416WK
		2F1	Carbon steel plating zinc flange 1 DN50	MDMAAGMU
		1M2	Stainless steel male M30×1.5	
		1F2	Stainless steel flange 2 DN10	
		1M1	Stainless steel male M42×1.5	
		1F1	Stainless steel flange 1 DN50	

Order Note

- 1. Please pay attention if the media is compatible with contacting material, especially pay attention to media density at measuring situation (except water);
- 2. We provide the user with PVC or polyurethane cable; polyurethane cable is more flexible and wearable. If the user has no special requirements, the default would be PVC cable;
- 3. If the product is installed in lightning and thunder area, please note "lightning Protection" in the order; we suggest to use lightning protection device to make sure power is grounding safely;
- 4. When MPM416WK transmitter's armoured tube more than 2m, we would provide the user with divided steel tube to help delivery. Please install tubes in local place;
 - 5. When MPM416WRK transmitter is working, please do not pull flexible steel tube to protect it;
 - 6. If the user has special requirement, please feel free to contact with our company.